

Centre de Technologie et d'Expertises

180 Avenue Charles Floquet 93155 LE BLANC MESNIL CEDEX (France)

33 (0) 1.48.14.71.00

∄ 33 (0) 1.48.14.71.34

Cancels and replaces the previous report n° 2016/R217 of August 18th, 2016

TEST REPORT N° 2016/ R 217a1

TEST ORDER: OB5858

DESCRIPTION OF TESTS:

Autogenous Ignition Test with Oxygen according to NF EN ISO 11114 – 3 and NF EN 1797 Standards on Krytox[™] PFPE Oils –VPF1525

Applicant: Chemours International Operations SARL
Dupont Meyrin Laboratory WX36
Route du Nant d'avril 146-CH-1217 Geneva
Switzerland

The Head of Center Olivier Beuneken

ORIGINAUX SIGNES

Technical Manager: Olivier Longuet

Technician(s): Dinesh Nadaradjane, Olivier Longuet

Distribution: Chemours International Operation SARL / Mme Claudine Picore (Claudine.picore@chemours.com)

Emission date: August 30th, 2016

This report includes 5 pages

Accreditation by the COFRAC certifies competency of the laboratories for only tests covered by accreditation

This report may not be reproduced other than in full



ACCREDITATION n° 1-2319 PORTEE DISPONIBLE SUR WWW.COFRAC.FR



Autogenous ignition test with oxygen according EN ISO 11114-3 and NF EN 1797 standards on Krytox[™] PFPE Oils –VPF1525

Cancels and replaces the previous report n°2016/R217 of August 18th, 2016

Date: August 30th 2016

Page: 2/5

SUMMARY

At the request of Chemours International Operations Company, we carried out an Autogenous ignition test with oxygen at test pressure of 120 bar according to NF EN ISO 11114-3 and EN 1797 standards on KrytoxTM PFPE Oils-VPF1525.

Tests Results:

 Up to 500 °C at 120 bar of oxygen, no autogenous ignition temperature was observed whereupon the testing was complete and discontinued.



The picture of the sample before the test, ref: KrytoxTM PFPE Oils-VPF1525

NOTA BENE: This report concerns only the samples that have been submitted to test.



Autogenous ignition test with oxygen according EN ISO 11114-3 and NF EN 1797 standards on Krytox[™] PFPE

Oils -VPF1525

Cancels and replaces the previous report n°2016/R217 of August 18th, 2016

Date: August 30th 2016

Page: 3/5

Auto-ignition sheet

AUTO IGNITION TEST

according to EN ISO 11114-3

Data sheet # : 5858

Test date : 05/07/2016 Request #: OB5858

Request by : Chemours International Operations SARL

Material : Krytox™ PFPE Oils - VPF1525

Function :

Supplier : Chemours International Operations SARL

Country: Switzerland 15/04/2016 Date of reception :

Conditions of use

Condition, shape, appearance: Liquid

Assumed composition :

Test conditions

EN ISO 11114-3 Standard applied : Weight of sample (g): 0.49 +/- 0.01

Medium : 02

RESULTS

Pressure in bar	Temperature in °C
Start	Start
120.9	
Peak	Peak
difference dP	difference dT

OBSERVATIONS

Up to 500 °C at 120 bar of oxygen, no autogenous ignition temperature was observed whereupon the testing was complete and discontinued

COMMENTS

Pressure :120.9 +/- 1 bar

Technical Manager Olivier Longuet

Technician Dinesh Nadaradjane

AIR LIQUIDE GLOBAL E&C solutions France SA

CENTRE DE TECHNOLOGIE ET D'EXPERTISES - LE BLANC MESNIL FORM-1-99-01




Autogenous ignition test with oxygen according EN ISO 11114-3 and NF EN 1797 standards on Krytox[™] PFPE Oils –VPF1525

Cancels and replaces the previous report n°2016/R217 of August 18th, 2016

Date: August 30th 2016

Page: 4/5

Test diagram





Autogenous ignition test with oxygen according EN ISO 11114-3 and NF EN 1797 standards on Krytox[™] PFPE Oils –VPF1525

Cancels and replaces the previous report n°2016/R217 of August 18th, 2016

Date: August 30th 2016

Page: 5 / 5



The picture of the sample after the spontaneous ignition test with oxygen

CONCLUSION

 Up to 500 °C at 120 bar of oxygen, no autogenous ignition temperature was observed whereupon the testing was complete and discontinued.